

Nexans Benelux
Alsebergsesteenweg 2, b 1
B-1501 Buizingen
Tel : + 32 (0)2 363 16 11
Fax : + 32 (0)2 363 16 31

We, NEXANS BENELUX, Alsebergsesteenweg 2 in 1501 BUIZINGEN, BELGIUM declare under our sole responsibility that the product

YMvK : Cross linked polyethylene insulated, polyvinyl chloride sheathed cables

from 1.5 till 6 sqmm and 2 to 5 conductors

to which this declaration relates is in conformity with the following standards or other normative documents provided that it is installed, maintained and used in the application for which it is made, with respect of the "professional practices", relevant installation standards and manufacturer's instructions :

- European standard
- International standard
- National standard
KEMA standards K42B-4
Cross linked polyethylene insulated cables
- sheathed cables for fixed wiring -
- Manufacturer's specification

following the provisions of Directive 73/23/EEG of 19.02.73 modified by Directive 93/68/EEG of 22.07.93.

Signature



Name and function
JJ. Versluis
Quality Engineer

Buizingen, 30 September 2004

END OF DOCUMENT

CE-IPRDe-032	ED. : 1 BLZ 1/1	DATE : 15.09.04	NEXANS BENELUX
--------------	-----------------	-----------------	----------------

CERTIFICATE

KEMA No.: 981110.01

Issued to:
Applicant:
NEXANS BENELUX S.A.
Rue Benoit, 1
ELOUGES (DOUR), Belgium

Manufacturer/Licensee:
NEXANS BENELUX S.A.
Rue Benoit, 1
ELOUGES (DOUR), Belgium

Product : cables for fixed wiring
Trade names : NEXANS BENELUX-B, NEXANS BENELUX-D
Type/model : YMvKmb

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard HD 604-4-D S1:1994/A1:1997
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 936886

KEMA hereby grants the right to use the KEMA-KEUR certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: March 22, 2001

C.M. Boschloo
Certification Manager

© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product : cables for fixed wiring
trade names : NEXANS BENELUX-B, NEXANS BENELUX-D
type : YMvKmb
rated voltage : 0,6/1 kV

TESTS**Test requirements**

HD 604-4-D S1:1994 en A1:1997
KEMA 42C-1-4-D:1995

Test results

The test results are laid down in KEMA test file 981110.01

Remarks

For the size of the certified cables see table III of the HD 604 S1:1994-Part 4, Section D. Cables with the cross-sections 1,5 and 2,5 mm² are certified for the number of conductors 1 up to and including 61.


This report is also based on and supersedes KEMA-KEUR report nos. 93.7715.01, 91.6444.01, 93.6886.01, 958861.02 and 26191.

Conclusion

The examination proved that all test requirements were met.

Tested by : A.A. Mackenbach

Checked by : H.J. Bouwman

**Factory-Locations**

NEXANS BENELUX S.A.,
Alsembergsesteenweg 2, BUIZINGEN, Belgium

NEXANS BENELUX S.A.,
Rue Benoit, 1, ELOUGES (DOUR), Belgium

KEMA Registered Quality B.V.

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET Arnhem, The Netherlands
Telephone +31 26 3 56 28 50, Telefax +31 26 3 52 58 00